

| 序号 | 规格       | 产品描述                                     | 正面照片                                                                                  |
|----|----------|------------------------------------------|---------------------------------------------------------------------------------------|
| 1  | A9Y53625 | 1P+N” 剩余电流动作保护模块 (25A/40A, AC/A类, 30mA)  |    |
| 2  | A9Y53640 | “1P+N” 剩余电流动作保护模块 (25A/40A, AC/A类, 30mA) |    |
| 3  | A9Y57625 | “1P+N” 剩余电流动作保护模块 (25A/40A, AC/A类, 30mA) |   |
| 4  | A9Y57640 | “1P+N” 剩余电流动作保护模块 (25A/40A, AC/A类, 30mA) |  |
| 5  | 917172   | “1P+N” 剩余电流动作保护模块 (25A/40A, AC类, 30mA)   |  |
| 6  | 917174   | “1P+N” 剩余电流动作保护模块 (25A/40A, AC类, 30mA)   |  |


|    |        |                                                          |                                                                                       |
|----|--------|----------------------------------------------------------|---------------------------------------------------------------------------------------|
| 7  | 917180 | “1P+N” 剩余电流动作保护断路器<br>(10A-40A, 4.5KA分断, C曲线, AC类, 30mA) |    |
| 8  | 917181 | “1P+N” 剩余电流动作保护断路器<br>(10A-40A, 4.5KA分断, C曲线, AC类, 30mA) |    |
| 9  | 917182 | “1P+N” 剩余电流动作保护断路器<br>(10A-40A, 4.5KA分断, C曲线, AC类, 30mA) |   |
| 10 | 917183 | “1P+N” 剩余电流动作保护断路器<br>(10A-40A, 4.5KA分断, C曲线, AC类, 30mA) |  |
| 11 | 917288 | “1P+N” 剩余电流动作保护断路器<br>(10A-40A, 4.5KA分断, C曲线, AC类, 30mA) |  |
| 12 | 917289 | “1P+N” 剩余电流动作保护断路器<br>(10A-40A, 4.5KA分断, C曲线, AC类, 30mA) |  |

|    |              |                                                            |                                                                                       |
|----|--------------|------------------------------------------------------------|---------------------------------------------------------------------------------------|
| 13 | EA9C65C1030C | “1P+N” 剩余电流动作保护断路器<br>(6-40A, 4.5KA/6KA分断, C曲线, AC类, 30mA) |    |
| 14 | EA9C65C1630C | “1P+N” 剩余电流动作保护断路器<br>(6-40A, 4.5KA/6KA分断, C曲线, AC类, 30mA) |    |
| 15 | EA9C65C2030C | “1P+N” 剩余电流动作保护断路器<br>(6-40A, 4.5KA/6KA分断, C曲线, AC类, 30mA) |   |
| 16 | EA9C65C2530C | “1P+N” 剩余电流动作保护断路器<br>(6-40A, 4.5KA/6KA分断, C曲线, AC类, 30mA) |  |
| 17 | EA9C65C3230C | “1P+N” 剩余电流动作保护断路器<br>(6-40A, 4.5KA/6KA分断, C曲线, AC类, 30mA) |  |
| 18 | EA9C65C4030C | “1P+N” 剩余电流动作保护断路器<br>(6-40A, 4.5KA/6KA分断, C曲线, AC类, 30mA) |  |

|    |                 |                                                            |                                                                                       |
|----|-----------------|------------------------------------------------------------|---------------------------------------------------------------------------------------|
| 19 | EA9C65C630C     | “1P+N” 剩余电流动作保护断路器<br>(6-40A, 4.5KA/6KA分断, C曲线, AC类, 30mA) |    |
| 20 | MGN911522       | “1P+N” 剩余电流动作保护断路器<br>(10A-20A, 4.5KA分断, C曲线, AC类, 30mA)   |    |
| 21 | MGN911523       | “1P+N” 剩余电流动作保护断路器<br>(10A-20A, 4.5KA分断, C曲线, AC类, 30mA)   |   |
| 22 | MGN911524       | “1P+N” 剩余电流动作保护断路器<br>(10A-20A, 4.5KA分断, C曲线, AC类, 30mA)   |  |
| 23 | MGNEA9C45C1030C | “1P+N” 剩余电流动作保护断路器<br>(6-40A, 4.5KA/6KA分断, C曲线, AC类, 30mA) |  |
| 24 | MGNEA9C45C1630C | “1P+N” 剩余电流动作保护断路器<br>(16A/20A, 4.5KA分断, C曲线, AC类, 30mA)   |  |

|    |                  |                                                            |                                                                                       |
|----|------------------|------------------------------------------------------------|---------------------------------------------------------------------------------------|
| 25 | MGNEA9C45C2030C  | “1P+N” 剩余电流动作保护断路器<br>(16A/20A, 4.5KA分断, C曲线, AC类, 30mA)   |    |
| 26 | MGNEA9C45C2530C  | “1P+N” 剩余电流动作保护断路器<br>(6-40A, 4.5KA/6KA分断, C曲线, AC类, 30mA) |    |
| 27 | MGNEA9C45C3230C  | “1P+N” 剩余电流动作保护断路器<br>(6-40A, 4.5KA/6KA分断, C曲线, AC类, 30mA) |   |
| 28 | MGNEA9C45C4030C  | “1P+N” 剩余电流动作保护断路器<br>(6-40A, 4.5KA/6KA分断, C曲线, AC类, 30mA) |  |
| 29 | MGNEA9C45C630C   | “1P+N” 剩余电流动作保护断路器<br>(6-40A, 4.5KA/6KA分断, C曲线, AC类, 30mA) |  |
| 30 | MGNEA9C45C1630CK | “1P+N” 剩余电流动作保护断路器<br>(16A/20A, 4.5KA分断, C曲线, AC类, 30mA)   |  |

|    |                  |                                                          |                                                                                       |
|----|------------------|----------------------------------------------------------|---------------------------------------------------------------------------------------|
| 31 | MGNEA9C45C2030CK | “1P+N” 剩余电流动作保护断路器<br>(16A/20A, 4.5KA分断, C曲线, AC类, 30mA) |    |
| 32 | A9V53240         | “2P” 剩余电流动作保护模块 (40A/63A, AC/A类, 30mA)                   |    |
| 33 | A9V53263         | “2P” 剩余电流动作保护模块 (40A/63A, AC/A类, 30mA)                   |   |
| 34 | A9V53663         | “1P+N” 剩余电流动作保护模块 (40A/63A, AC/A类, 30mA)                 |  |
| 35 | A9V53640         | “1P+N” 剩余电流动作保护模块 (40A/63A, AC/A类, 30mA)                 |  |
| 36 | A9V53440         | “4P” 剩余电流动作保护模块 (40A/63A, AC/A类, 30mA)                   |  |

|    |          |                                          |                                                                                       |
|----|----------|------------------------------------------|---------------------------------------------------------------------------------------|
| 37 | A9V53463 | “4P” 剩余电流动作保护模块 (40A/63A, AC/A类, 30mA)   |    |
| 38 | A9V57440 | “4P” 剩余电流动作保护模块 (40A/63A, AC/A类, 30mA)   |    |
| 39 | A9V57463 | “4P” 剩余电流动作保护模块 (40A/63A, AC/A类, 30mA)   |   |
| 40 | A9V57240 | “2P” 剩余电流动作保护模块 (40A/63A, AC/A类, 30mA)   |  |
| 41 | A9V57263 | “2P” 剩余电流动作保护模块 (40A/63A, AC/A类, 30mA)   |  |
| 42 | A9V57640 | “1P+N” 剩余电流动作保护模块 (40A/63A, AC/A类, 30mA) |  |

|    |            |                                         |                                                                                       |
|----|------------|-----------------------------------------|---------------------------------------------------------------------------------------|
| 43 | A9V57663   | “1P+N” 剩余电流动作保护模块(40A/63A, AC/A类, 30mA) |    |
| 44 | EA9B26330C | “2P” 剩余电流动作开关(63A, AC类, 30mA)           |    |
| 45 | EA9B22530C | “2P” 剩余电流动作开关(25A/40A, AC类, 30mA)       |   |
| 46 | EA9B24030C | “2P” 剩余电流动作开关(25A/40A, AC类, 30mA)       |  |
| 47 | EZ713225   | 2P” 剩余电流动作开关(25A/40A, AC类, 30mA)        |  |
| 48 | EZ713240   | “2P” 剩余电流动作开关(25A/40A, AC类, 30mA)       |  |

|    |           |                                    |
|----|-----------|------------------------------------|
| 49 | LS8R13225 | “2P” 剩余电流动作开关 (25A/40A, AC类, 30mA) |
| 50 | LS8R13240 | “2P” 剩余电流动作开关 (25A/40A, AC类, 30mA) |





1

2







|

1

2

.

|

.

1